

**Materialprüfungsamt Nordrhein-Westfalen**

Prüfen • Überwachen • Zertifizieren

**Certificate of constancy of performance****0432-CPR-00099-13**

Version 03

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

**Stay arm door coordinator ECO SR Basis, ECO SR Basis (TT),  
ECO SR Basis (2V, M8x35), ECO SR Basis (2VR), ECO SR Basis (4)**

Door coordinators for double-leaf doors in accordance with the composition and classification in annex 1 placed on the market under the name or trade mark of

**ECO Schulte GmbH & Co. KG**

Iserlohner Landstraße 89  
58706 Menden, Germany

and produced in the manufacturing plant(s)

**DO 2.30**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard(s)

**EN 1158: 1997/A1:2002/AC:2006**

under **system 1** for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 01.08.2018 and will remain valid until 01.08.2028 as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Dortmund, 01.08.2023



By order

RBA Thorsten Meinks  
Deputy Head of Certification Body Department  
22.30

This Certificate consists of 1 page and 1 annex(es).

This Certificate replaces the Certificate no. 0432-CPR-00099-13 dated 22.04.2022,  
Version 02.

The original of this document was issued in German language.



## List of Products

<b>Type :</b>	Stay arm door coordinator ECO SR Basis, ECO SR Basis (TT), ECO SR Basis (2V, M8x35), ECO SR Basis (2VR), ECO SR Basis (4)
<b>Description :</b>	Door coordinator for double-leaf-doors
<b>Size :</b>	3 - 7
<b>Classification :</b>	3 5 3-7 1 1 3
<b>Manufacturing plant :</b>	DO 2.30
<b>Remarks :</b>	<p>the carry bar „MK Basis 1“ is always required if the correct closing sequence of both door leaves is not achieved.</p> <p>ECO SR Basis (TT): type with adjustable stay arm.</p> <p>ECO SR Basis (2V, M8x35): type with adjustable stay arm and angle bracket with reinforcement bead.</p> <p>ECO SR Basis (2VR): type with adjustable stay arm, angle bracket with reinforcement bead and without counterbore on mounting holes.</p> <p>ECO SR Basis (4): type with four mounting holes.</p>

### Intended use:

For single- and double leaf fire- and/or smoke protection doors

Essential properties	Clauses with requirements in EN 1158:1997/A1:2002/AC:2006	Performance of the product
Self-closing	5.1.2 Completeness of the products 5.1.3 Correct closing sequence 5.2.1 General 5.2.2 Overload behaviour in closing direction 5.2.3 Manipulation 5.2.4 Resistance in waiting position 5.2.6 Damage 5.2.8 Use on fire-/ smoke protection doors	Passed Passed (Size 3-7) Passed Passed (Size 3-7) Passed (Size 3-7) Passed (Size 3-7) Passed (Size 3-7) Class 1: Passed
Durability of Self-closing	5.2.5 Durability 5.2.7 Corrosion resistance 5.2.7.1 5.2.7.2 5.2.7.3	Class 5 (50.000 Cycles): Passed  Class 3 (96h): Passed Class 3 (96h): Passed Class 3 (96h): Passed
Dangerous substances	Annex ZA.3	The manufacturer has not declared any dangerous substances.