Declaration of performance No. DOP-1154-EN3-6-00099-24



1. U	niaue	code	for	the	product	tvpe
------	-------	------	-----	-----	---------	------

ECO ITS-630 (3-6)

2. Purpose of application or purposes of application intended by the manufacturer of the construction product in accordance with the applicable harmonised technical specification:

Controlled closing of single- and double-leafed doors for fire/smoke resistance closures

3. Name, registered brand name or registered brand and contact address of the manufacturer in accordance with Article 11, Paragraph 5:

ECO Schulte GmbH & Co. KG Iserlohner Landstraße 89 D-58706 Menden

4. If appropriate, name and contact address of the authorised representative who is assigned to the tasks in accordance with Article 12, Paragraph 2:

N/A

5. Harmonised standard:

EN 1154:1996/A1:2002/AC:2006

6. Notified body:

The notified certification body for in-house production checks **no. 0432** has carried out the initial inspection of the manufacturing plant and factory production checks as well as the continuous monitoring, assessment and evaluation of the factory production checks and has issued the certificate of conformity of factory production checks **(to 0432-CPR-00099-24)**.

Notified product certification body no. 0432

Declaration of performance No. DOP-1154-EN3-6-00099-24



7. Declared performance:

Essential characteristics	Performance	Harmonised technical specification
Self-closing		
5.2.1 General	Passed	
5.2.3 Closing torque	Size 3-6: Passed	
5.2.4 Opening torque	Size 3-6: Passed	
5.2.5 Efficiency	Size 3-6: Passed	
5.2.6 Closing time	Passed	
5.2.7 Opening angle	Class 3: Passed (internal montage)	
5.2.8 Overload test	Passed	
5.2.9 Temperature dependence	Size 3-6: Passed	
5.2.10 Leakage	Size 3-6: Passed	
5.2.11 Damage	Size 3-6: Passed	
5.2.12 Latch regulation	Size 3-6: Passed	
5.2.13 Back check	Size 3-6: Passed	EN 1154:1996/A1:2002/AC:2006
5.2.14 Delayed action	NPD	EN 1154:1990/A1:2002/AC:2006
5.2.15 Adjustable force	Size 3-6: Passed	
5.2.16 Play in zero point position	NPD	
5.2.18 Use on fire-/smoke resistance doors	Class 1: For use on fire-/smoke resistance doors acc. to a test of EN 1634-1	
Durability self-closing		
5.2.2 Drability	Class 8: 500,000 cycles	
5.2.17.1 Corossion resistance	Class 3: high corrosion resistance (96h)	
5.2.17.2 Corossion resistance	Class 3: high corrosion resistance (96h)	
5.2.17.3 Corossion resistancet	Class 3: high corrosion resistance (96h)	
Dangerous substances		
ZA.3 Dangerous substances	The materials used in this product do not contain or release any dangerous substance	

Declaration of performance No. DOP-1154-EN3-6-00099-24



8. Suitable technical specification and/or specifical technical documentation	n:
N/A	
The performance of the above products complies with the declared performance in a	
Tobias Schulte, Managing Director of ECO Schulte GmbH & Co. KG (Signatory Name and function in company)	J. Schults
Menden, 11.03.2024 (Place and date of issue)	(Signature)