Declaration of performance No. DOP-1154-EN1-5-00099-10



1. I	Unique	code	for th	ne proc	duct ty	pe:
------	--------	------	--------	---------	---------	-----

ECO TS-50 EN 1-5

2. Purpose of application or purposes of application intended by the manufacturer of the construction product in accordance with the applicable harmonised technical specification:

Controlled closing of single- and double-leafed doors for fire/smoke resistance closures

3. Name, registered brand name or registered brand and contact address of the manufacturer in accordance with Article 11, Paragraph 5:

ECO Schulte GmbH & Co. KG Iserlohner Landstraße 89 D-58706 Menden

4. If appropriate, name and contact address of the authorised representative who is assigned to the tasks in accordance with Article 12, Paragraph 2:

N/A

5. Harmonised standard:

EN 1154:1996/A1:2002/AC:2006

6. Notified body:

The notified certification body for in-house production checks **no. 0432** has carried out the initial inspection of the manufacturing plant and factory production checks as well as the continuous monitoring, assessment and evaluation of the factory production checks and has issued the certificate of conformity of factory production checks **(to 0432-CPR-00099-10)**.

Notified product certification body no. 0432

Declaration of performance No. DOP-1154-EN1-5-00099-10



7. Declared performance:

Essential characteristics	Essential characteristics Performance		
Self-closing	•		
5.2.1 General	Passed		
5.2.3 Closing torque	Size 1-5: Passed		
5.2.4 Opening torque	Size 1-5: Passed		
5.2.5 Efficiency	fficiency Size 1-5: Passed		
5.2.6 Closing time	sing time Passed		
5.2.7 Opening angle	Class 3: Passed (Frame fixing in the closing side) Class 4: Passed (Door leaf fixing on the opening side)		
5.2.8 Overload test	Passed		
5.2.9 Temperature dependence	Size 1-5: Passed		
5.2.10 Leakage	Size 1-5: Passed		
5.2.11 Damage	Size 1-5: Passed		
5.2.12 Latch regulation	h regulation Size 1-5: Passed		
5.2.13 Back check	Size 1-5: Passed	EN 1154:1996/A1:2002/AC:2006	
5.2.14 Delayed action	NPD		
5.2.15 Adjustable force	Size 1-5: Passed		
5.2.16 Play in zero point position	NPD		
5.2.18 Use on fire-/smoke resistance doors	Class 1: For use on fire-/smoke resistance doors acc. To a test of EN 1634-1		
Durability self-closing			
5.2.2 Drability	Class 8: 500,000 cycles		
5.2.17.1 Corossion resistance	Class 3: high corrosion resistance (96h)		
5.2.17.2 Corossion resistance	Corossion resistance Class 3: high corrosion resistance (96h)		
5.2.17.3 Corossion resistancet	rossion resistancet Class 3: high corrosion resistance (96h)		
Dangerous substances			
ZA.3 Dangerous substances	The materials used in this product do not contain or release any dangerous substance		

Declaration of performance No. DOP-1154-EN1-5-00099-10

Menden, 23.08.2023 (Place and date of issue)

8. Suitable technical specification and/or specifical technical documentation:



The performance of the above products complies with the declared performances. The manufacturer mentioned above is solely responsible for drawing up the declaration of performance in accordance with Regulation (EU) no. 305/2011.							
J. Schulte							

(Signature)